
Single-Phase, Slim, Power Controller

Features

- Slim size (50mm width)
- Auto/Manual input control available
- Switch between RUN (close)/STOP (open) using terminal
- Phase control for various load control and zero-cross cycle control (variable cycles)
- Built-in fast-acting fuse for internal circuit protection (optional)
- Various alarm outputs: overcurrent alarm, heatsink overheat alarm, load disconnection alarm, SCR error alarm





SENSORS

CONTROLLERS

MOTION DEVICES

SOFTWARE

(J) Temperature Controllers

(M) Counters

(P) Indicators

(Q) Converters

(R) Digital Display Units


(S) Sensor Controllers


(T) Switching Mode Powe Supplies

(U) Recorders


(X) Field Network







Connections



XR, S, U terminals are at the bottom of the unit. For wiring terminals, open the front cover.

DPUS Series

■ Specifications

Series		DPUS2-025	DPUS3-025	DPUS4-025				
Control p	hase	Single-phase						
Power su	upply	220VAC~	380VAC~	440VAC~				
Allowable	e voltage range	range 90 to 110% of rated voltage						
Rated fre	equency	50/60Hz (auto recognition), allowable frequency range: ±2Hz (performance guarantee: ±1Hz)						
Rated cu	ırrent	25A						
Power co	onsumption	Max. 5W						
Min. load	d current	3A						
Output ra	output range Phase control: 0 to 98% Variable cycle control: 0 to 100%							
Output a	ccuracy	Within ±10% F.S. of rated voltage						
Control n	nethod	Phase control, variable cycle contr	rol					
Load		Resistance load						
Indicator		Indicates LED status						
Setting method		Setting by front DIP switches and a rotary switch						
Control input		Auto: DC4-20mA / 1-5VDC== Manual: inside adjuster 10kΩ, outside adjuster 10kΩ (min. 2W)						
DIP switch input		Phase control/variable cycle control, voltage/current input, AUTO/MANUAL, ramp operation, over current alarm/current limit, load recognition mode, inside/outside adjuster						
Rotary switch input		Output setting: 10 to 100% over current and load disconnection alarm setting						
Dielectric	strength	2,000VAC 50/60Hz for 1 min (between input terminal and power terminal)						
Vibration	1	0.75mm amplitude at frequency of 5 to 55Hz (for 1 min) in each X, Y, Z direction for 2 hours						
Insulation	n resistance	Over 200MΩ (at 500VDC megger)						
Noise im	munity	±2kV the square wave noise (pulse width 1μs) by the noise simulator						
Environ-	Ambient temp.	-10 to 50°C, storage: -20 to 80°C						
ment	Ambient humi.	30 to 85%RH, storage: 30 to 85%RH						
Approval	<u> </u>	CE .						
Weight*1	1	Approx. 980g (approx. 880g)						

X1: The weight includes packaging. The weight in parenthesis is for unit only.

Dimensions

04.2 M4

DPUS

Autorites

Autorites

157


(unit: mm)

L-52 Autonics

^{*}Environment resistance is rated at no freezing or condensation.

Single-Phase, Slim, Power Controller





5. Rotary switch

Set current limit output (10 to 100%). Factory default: 0

Position	1	2	3	4	5	6	7	8	9	0
SV	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%


6. DIP switch

Dir Owiton								
Position	1	2	3	4	5	6	7	8
1()[X]	Current input (DC4-20mA)		ΙΝΛΔΝΙΙΙΔΙ	ioneration ()ixi	Load recognition mode ON	Current limit		Inside adjuster
OFF	Voltage input (1-5VDC)	Variable cycle control	AUTO	Ramp operation OFF	Irecognition	Overcurrent alarm	_	Outside adjuster

Factory default: All DIP switches OFF

7. Power input and load connection part

Placed at the bottom of the unit. For wiring terminals, open the front cover.



8. Front cover

Open the front cover, there are the rotary switch, DIP switch, power input part.

9. Terminal block

SENSORS

CONTROLLERS

MOTION DEVICES

SOFTWARE

(J) Temperature Controllers

K) SSRs

(L) Power Controllers

(M) Counters

(N) Timers

(O) Digital Panel Meters

(P) Indicators

(Q) Converters

(R) Digital Display Units

(S) Sensor Controllers

(T) Switching Mode Power Supplies

(U)

(U) Recorders

(V) HMIs

(W) Panel PC

(X) Field Network Devices

Autonics L-5

DPUS Series

Functions

O Ramp operation [DIP switch 4 ON]

When controlling the load which has inrush current (platinum, molybdenum, tungsten, infrared lamp, etc) in power ON, or when control input changes rapidly, it prevents the load to increase output gradually within the set time. Regardless of control method setting, Ramp operation increases/decreases input value.

The time for output to reach 0 to 100% (current limit output value) is fixed at 10 sec.

○ RUN/STOP [5-6 terminals]

It switches RUN (close)/STOP (open) by terminal input. RUN mode operates as the set value by control input. STOP mode is standby status.

○ AUTO/MANUAL selection [DIP switch 3 ON/OFF]

- 1) AUTO: Mode for controlling the output by analog input.
- 2) MANUAL: Mode for controlling the output by adjusting inside or outside adjuster as control input adjuster.


	,			
Selection			Input impedance	DIP switch
AUTO input (DIP switch	Current	DC4-20mA	100Ω	DIP switch 1 ON
3 OFF)	Voltage	1-5VDC	13kΩ	DIP switch 1 OFF
MANUAL input	Inside adjuster	10kΩ	_	DIP switch 8 ON
(DIP switch 3 ON)	Outside adjuster	10kΩ	_	DIP switch 8 OFF

%For setting by the inside adjuster, do not use the outside adjuster.

Control method


1) Phase control [DIP switch 2 ON]

It controls proportionally a phase angle according to control input with half cycle.



It controls phase angle proportional to control input (DC4-20mA or 1-5VDC) level.

- · 25% of control input signal
- · 50% of control input signal
- · 75% of control input signal




X1: Black parts of output waves are output value as applied to the load.

2) Variable cycle control [DIP switch 2 OFF]

It optimizes the number of AC voltage cycles supplied to the load by control input proportionally and controls the subject fast and correctly.


 \cdot 10% of control input signal



· 25% of control input signal

T cycle

ignal · 50% of control input signal



L-54 Autonics

Single-Phase, Slim, Power Controller

Alarm

Туре	Status indicator	Operation	Clear alarm	
Overcurrent	Flashes red LED by 0.5 sec			
Heatsink overheat	Flashes red LED by 0.3 sec	Output stop (SCR OFF)	RESET switch or Power resupply	
Thyristor error	Flashes green/red LED interval			
Current limit	Flashes orange LED by 0.5 sec	Current limit output	Automatically clear at alarm clear	IJ
Load disconnection	Flashes green LED by 0.5 sec	Operation maintain	conditions	

O Current alarm

Current alarm is available only in phase control mode. Set alarm current value by the rotary switch.


1) Overcurrent alarm (DIP switch 6 OFF):

When current reaches to the set current limit value, the set alarm occurs and output stops (flashes red LED by 0.5 sec). To clear this alarm, re-supply the power or press the RESET key.

2) Current limit (DIP switch 6 ON):

Current limit function limits output to prevent not to flow over the rated current (flashes orange LED by 0.5 sec).

*When operating current limit, it may cause over shoot temporarily.



Heatsink overheat alarm

When the temperature of a heatsink is over 90° C, heatsink overheat alarm occurs (flashes red LED by 0.3 sec). To clear this alarm, re-supply the power or pres s the RESET key.

Thyristor error alarm

If current flows over 3A even though output is 0%, element error alarm occurs. When element error alarm occurs, output stops (flashes green/red LED interval). To clear this alarm, re-supply the power or press the RESET key.


O Load disconnection alarm [Power OFF after DIP switch 5 ON]

Load disconnection alarm is available after measuring load resistance value by load recognition mode (DIP switch 5 ON). When load resistance value is over than disconnection alarm SV, alarm occurs (load disconnection alarm occurs regardless of output value) and control operation is maintained (flashes green LED by 0.5 sec).

For output voltage is below 15V or output is 10%, load disconnection alarm does not operate.

When load resistance value is lower than the load disconnection alarm SV, this alarm cleared automatically.

· How to set load recognition mode



- X1: When setting as 0, load disconnection alarm does not operate.
- ※2: Do not use the load which has the problem with 50% output.
- X3: When output is lower than the load disconnection alarm SV set by the rotary switch, load disconnection alarm occurs.

Proper Usage

- In order to prevent electric shock, this unit should be grounded.
 Otherwise, mount the unit on the solid metal conductor which is grounded.
- Install the unit vertically at the well ventilated place.
- Install the unit at the access restriction area.
 - **Access restriction area: a electric expert with delegated authority or a well trained electric expert only accessible area.
- Be sure that if using this unit over the rated current, it may cause damage to the unit directly.
- Select the proper cable for connecting power and load to flow the rated current enough by the cable standard.
- In order to open the front cover, the power supply should be cut off.
 Before replacing, wiring it, be sure that turn OFF the power of input and load parts and check the safety.
- This product may be used in the following environments.
 - ① Indoors

- ② Max. altitude: 2,000m
- ③ Pollution degree 2
 ④ Installation category II

SENSORS

CONTROLLERS

MOTION DEVICES

SOFTWARE

(J) Temperature Controllers

(K) SSRs

(L) Power Controllers

(M) Counters

(N) Timers

(O) Digital Panel Meters

(P) Indicators

(Q) Converters

(R) Digital Display Units

(S) Sensor Controllers

(T) Switching Mode Power Supplies

> (U) Recorders

(V) HMIs

(W) Panel PC

(X) Field Network Devices

Autonics L-55