Bar Graph Temperature Indicators

Features

- High accuracy with 16 bit ADC (±0.2% F.S.)
- Multi-input
 - Thermometer 12 types
 - RTD 5 types
 - Analog: current 2 types/voltage 4 types
- 101 LED bar graph (green)
- · Various output options
 - Alarm output: 2 points/4 points - 4-20mA transmission output (isolated), RS485 communication output
- · Various functions
 - Bar graph alarm display
 - High/Low peak input monitoring
 - Alarm output (upper/lower, sensor break)

- Transmission output/display scale
- Digital input (DI), etc.
- Built-in power supply for sensor/transmitter (24VDC)

Small size (rear length: 70mm)

Please read "Safety Considerations" in the instruction manual before using


Ordering Information



KN - 1 0 0 0 B		
Size	В	DIN W36×H144mm
Power supply	0	100-240VAC 50/60Hz
	1	24VDC
	0	No option
Option output	1	Transmission output (4-20mA)
	4	RS485 communication output
	0	No alarm output
Alarm output	2	Alarm output: 2
	4	Alarm output: 4
Item	KN-1	Bar Graph Temperature Indicators

CE


Dimensions




(unit: mm)

Connections


● KN-10□□B







● KN-14□ □B



Specifications


Series		KN-1000B		
Power	AC voltage	100-240VAC~ 50/60Hz		
supply	DC voltage	24VDC		
Allowable vol	tage range	90 to 110% of rated voltage		
Power con-	AC voltage	Max. 6VA		
sumption	DC voltage	Max. 4W		
Display meth	od	7-segment LED (red), graphic bar (green) LED method		
	RTD	JPt100Ω, DPt100Ω, DPt50Ω, Cu50Ω, Cu100Ω (5 types)		
Input type	Thermocouple	K, J, E, T, R, B, S, N, C (W5), L, U, PLII (12 types)		
input type	Analog	· Voltage: ±1.000V, ±50.00mV, -199.9-200.0mV, -1.00-10.00V (4 types) · Current: 4.00-20.00mA, 0.00-20.00mA (2 types)		
Digital input		 Contact input: max. 2kΩ in ON, min. 90kΩ in OFF Non-contact input: residual voltage max. 1.0V in ON, leakage current max. 0.03mA in OFF Outflow current: approx. 0.2mA 		
o	Alarm output	2-point: relay contact capacity 250VAC \sim 3A 1c 4-point: relay contact capacity 250VAC \sim 1A 1a		
Sub output	Transmission output	ISOLATED DC4-20mA(PV transmission) load resistance max. 600Ω		
	Communication output	butput RS485 (Modbus RTU)		
Display accuracy		±0.2% F.S. ±1-digit (25°C±5°C), ±0.3% F.S. ±1-digit (~10°C to 20°C, 30°C to 50°C) In case of thermocouple and below -100°C input, [±0.4%F.S.] ±1-digit %TC-T. TC-U is min. ±2.0°C		
Setting metho	bd	Set by front keys, or RS485 communication		
Alarm output hysteresis		Set ON/OFF interval (1 to 999-digit)		
Sampling cyc	le	Analog input: 100ms, temperature sensor input: 250ms		
Dielectric volt	age	2000VAC 50/60Hz for 1 min (between input terminal and power terminal)		
Vibration		0.75mm amplitude at frequency 5 to 55Hz (for 1 min) in each X, Y, Z direction for 2 hours		
Relay	2-point	Mechanical: min. 10,000,000, electrical: min. 100,000 (250VAC 3A resistance load)		
life cycle	4-point	Mechanical: min. 20,000,000, electrical: min. 500,000 (250VAC 1A resistance load)		
Insulation res	istance	Over 100MΩ (at 500VDC megger)		
Noise immunity		±2kV the square wave noise (pulse width 1µs) by noise simulator		
Memory reter	ntion	Approx. 10 years (non-volatile semiconductor memory type)		
Environment Ambient temperature		−10 to 50°C, storage: −20 to 60°C		
	Ambient humidity	35 to 85%RH, storage: 35 to 85%RH		
Approval		CE		
Weight ^{×1}		Approx. 304g (approx. 182g)		

X1: The weight includes packaging. The weight in parenthesis is for unit only.

* Environment resistance is rated at no freezing or condensation.

Input Type and Range

Input type selection switch



This unit is multi input product. Select the proper input with the input type selection switch and select this input type in l n P in program mode. The setting of input type selection switch and the input type l n P parameter should be same and it can display the proper measurement value. Factory default is 0-20mA.

Input type			Parameter	Input range(°	C)	Input range(°	F)
	K(CA)		E C.2 1	-200	to 1350	-328	to 2462
	K(CA)	K(CA)		-199.9	to 999.9	-328	to 1832
	J(IC)	J(IC)		-199.9	to 800.0	-328	to 1472
	E(CR)		FC-E	-199.9	to 800.0	-328	to 1472
	T(CC)		£[-£	-199.9	to 400.0	-199.9	to 752.0
	B(PR)*		ЕС-Б	100	to 1800	212	to 3272
Thermocouple	R(PR)		EC-r	0	to 1750	32	to 3182
	S(PR)*		EC-5	0	to 1750	32	to 3182
	N(NN)*		EE-n	-200	to 1300	-328	to 2372
	C(W5)*		FE-E	0	to 2300	32	to 4172
	L(IC)*	L(IC)*		-199.9	to 900.0	-328	to 1652
	U(CC)*	U(CC)*		-199.9	to 400.0	-199.9	to 752.0
	Platinel II*		EC-P	0	to 1390	32	to 2534
	Cu50Ω*		C U.S D	-199.9	to 200.0	-199.9	to 392.0
	Cu100Ω*		E U. 10	-199.9	to 200.0	-199.9	to 392.0
RTD	JPt100Ω		JPE. I	-199.9	to 600.0	-328	to 1112
	DPt50Ω		dPE.S	-199.9	to 600.0	-328	to 1112
	DPt100Ω	DPt100Ω		-199.9	to 850.0	-328	to 1530
	Current	0.00 - 20.00mA	8.581		÷	· · · ·	
	Current	4.00 - 20.00mA	R.5.8.2				
	Voltage -199.9	-50.0 - 50.0mV	R.ñu I	– 1999 to 999	– 1999 to 9999 (display range depends on the decimal point position)		
Analog		-199.9 - 200.0mV	R.ñ u 2	(display range			
		-1.000 - 1.000V	R-u I				
		-1.00 - 10.00V	8-u2	7			

%Above input types which have the * mark are not displayed.

1

2

3

(4)

5

 \times To display the above input types, supply the power with pressing the \mathbb{M} key.

Unit Descriptions

INDICATOR

5 18

60

M

≪

୲

5

മ്പിരവിദ

(8)

1

6

- ① Display part (red)
 - Run mode: Displays current measurement value.
 - Parameter set mode: Displays parameter and SV.
- 2 Unit sticker part (unit sticker is an accessory.)
- ③ Alarm output indicator: Turns ON when the alarm is ON.
- ④ M key: Used to enter parameter set mode, move to parameters, save SV and return to RUN mode.
- ⑤ K, ⋈, ⋈ key: Used to enter and change parameter SV.
- ⑥ D.IN3: Press the A and A keys for 3 sec at the same time, it operates the set function (alarm clear, display hold, zero-point adjustment) at d₁ - t² at program mode.
- ⑦ Bar Graph (with 101 bar LEDs, green): Displays measured value as bar graph.

(8) Space for recognition device by user

■ Alarm [AL - 1, AL - 2, AL - 3, AL - 4]

This product has 2 or 4 alarms to operate individually when the value is too high or low. Alarm function is set by the combination of alarm operation and alarm option. To clear alarm, use digital input function (setting $d_1 - \xi$, $d_1 - \xi$ as RL, rE) or turn the power OFF and ON.

%For the model (KN-10 B) without alarm output, these parameters are not displayed.



—— Alarm operation

○ Alarm operation

Mode	Name	Alarm operation	Descriptions
AF 0	—	-	No alarm operation
AF ([])	High limit alarm	OFF H ON High limt alarm value: 800°C	PV ≥ alarm temperature, alarm is ON
AF 5:[]	Low limit alarm	ON H OFF Low limt alarm value: 200°C	PV ≤ alarm temperature, alarm is ON
56R	Sensor break alarm	-	It will be ON when it detects sensor disconnection. Sensor break alarm does not have alarm option.


% H: Alarm output hysteresis


○ Alarm option

-		
Mode	Name	Descriptions
AF 🖸 A	Standard alarm	If it is an alarm condition, alarm output is ON. Unless an alarm condition, alarm output is OFF.
ЯЕ∭Ь	Alarm latch	If it is an alarm condition, alarm output is ON. Before clearing the alarm, an ON condition is latched. (Holding the alarm output)
RE[]]C	Standby sequence	First alarm condition is ignored. From the second alarm condition, standard alarm operates. When power is ON and it is an alarm condition, it is ignored. From the second alarm condition, standard alarm operates.
RE∭d	Alarm latch and standby sequence	If it is an alarm condition, it operates both alarm latch and standby sequence. When power is ON and it is an alarm condition, it is ignored. From the second alarm condition, alarm latch operates.

■ Alarm output hysteresis [Program mode: R - H 4]

Set the interval of ON/OFF alarm output. The set hysteresis is applied to AL1 to AL4 and it is as below.





■ High/Low peak monitoring [Monitoring mode: H.PEŁ, L.PEŁ]

This function is to save high/low peak to check the invisible abnormal condition of system at [HPEP] or [LPEP] in monitoring mode.

When the high/low peak is out of the temperature range, it displays HHHH or LLLL.

To initialize high/low peak, press the B, V keys at the same time for 3 sec at [HPEL] or [LPEL].

In this case, peak value is the present input value.

Error

Display	Descriptions	Troubleshooting
LLLL	Flashes when measured sensor input is lower than the temperature range.	When input is moved within the
	Flashes when measured sensor input is higher than the temperature range	temperature range, it is cleared.
	Flashes when the sensor is break or not connected.	Check temperature sensor connection.
Err	Flashes when there is error to SV	Check set conditions and re-set it.

■ Temperature unit [Program mode: Unite]


Temperature unit (°C/°F) is selectable. When changing temperature unit, user input range, display scale, output scale, alarm SV are initialized. You should set the parameters again for your purpose.

When selecting analog input, temperature unit [Uni E] parameter is not displayed.

Parameter initialization

To initialize all parameter as factory default, supply the power to the product with pressing the $\boxed{\mathbb{M}}$ and $\boxed{\mathbb{K}}$ keys at the same time and it enters initialization parameter.

Press the **M** +**≪** keys at the same time.



Decimal point [Program mode: d.P]


It is able to change decimal point position for high/low limit scale value. It changes decimal point position of display value.

Transmission output scale

[Program mode: Lout, Hout]

For 4-20mA current output, this function is to set the display value for $4mA [L_{\Box} U E]$ and the display value for $20mA [H_{\Box} U E]$.

The interval between L_{DUE} and H_{DUE} is 10% F.S. If it is below 10%, it is fixed as 10% of SV.




User input range [Program mode: L - - D, H - - D]

When selecting analog input, you can set the input range for your purpose. Set low limit input value [$L - r\overline{L}$] and high limit input value [$H - r\overline{L}$] to limit the input range.

- · Setting range
 - : Low limit input value [L-rG]+20%F.S.
 - < High limit input value [H r G]

Display scale [Program mode: L-5[, H-5[]

For analog input, this function is to set (-1999 to 9999) for particular high/low limit value in order to display high/low limit value of measurement input. If measurement inputs are 'a' and 'b' and particular values are 'A' and 'B', it will display a=A, b=B as below graphs.





Display scale function is able to change display value for max./min. measured input by setting high limit scale [H-5L] and low limit scale [L-5L] in program mode.

%E.g.) Set high/low scale value (input range is 0 to 10V)

- L-5C=0.00
- H-5C=5.00, 10.00, 15.00, ⊣0.00







When changing input type, high/low scale is changed as factory default.

■ Input correction [Program mode: I n-b]

This function is to correct the error occurring from a thermocouple, a RTD or analog input out of allowable error range of this unit.

This is also available to correct error when a sensor cannot contact the subject position by calculating the error temperature.

Variable temperature sensors have accuracy level. Because high accuracy type is expansive, standard thermocouples are generally used.

In this case, temperature sensor may occur error. By executing this function, you can get more accurate temperature.

When executing input correction function, you should measure the error from a sensor accurately. If the measured error is not correct, error may be greater.

(If $I_{n,5}F = E \sqcup F$, I_{n-b} as atmospheric pressure input value not as input correction function. Refer to '**T** Two unit function'.)


E.g.)When measured temperature is 4°C and actual temperature is 0°C. Set *I* n - b as -4, and display value is 0°C.

Bar graph scale [Program mode: L-b5, H-b5]

This is to set display range for bar graph. Display range is as below.

Parameter	Input	Display range	
L-65	Temp. sensor input	Input range (low limit) ≤ L - b5 ≤ (H - b5 -1)	
	Analog input	L-5C ≤L-65 ≤ (H-5C-1)	
Н-65	Temp. sensor input	(と⁻Ხ与+1) ≤HーᲮ与≤ ^{Input} range (high limit)	
	Analog input	(L-5C+1) ≤H-65 ≤ H-5C	

※Relation among input range, user input range, display scale, bar graph scale, and transmission scale The below figure is the example for 4 to 20mA.




■ Bar graph display method [Program mode: bRr]

There are two methods for bar graph display; full bar and center bar.

Full bar [F.bBr] displays input from the bottom, and center bar method [L.bBr] displays input from "0" as below figures.

Ж E.g.)When L - Ь5 = −100, H - Ь5 = 100, PV = −50,



■ Input and transmission output extension [Program mode: E \./ □]

This function is to extend analog input and 4 to 20mA transmission output to 5% or 10% range.

Mode	Operation
OP	Outputs 4 to 20mA within analog input range.
5.P	Outputs 3.2 to 20.8mA for 5% out of the analog input range.
	Outputs 2.4 to 21.6mA for 10% out of the analog input range.

※ This parameter is displayed only for transmission output (4-20mA) model. But it is not displayed when selecting temperature sensor input.

% The below of 0mA, 0V cannot be extended.

%±1V, 10V inputs are only available for 5% extension.

Alarm display in bar graph

When setting or occurring the alarm, it displays the status by the bar graph.

You can check the alarm status. When setting alarm value, the bar LED for this alarm value turns ON. When alarm occurs, the bar LED for this alarm value flashes.

① When setting alarm value,


The bar LED for alarm SV flashes. When alarm set is complete, the bar LED for this alarm value turns ON.

- ② RUN mode
 - · All set alarm values are displays in RUN mode.
 - When it is alarm value, the bar LED for this alarm value flashes.

※If alarm set value is out of bar graph scale when setting the value or in RUN mode, this value does not display in bar graph.

○ When setting alarm value in monitoring mode,






% The bar LED for the alarm value flashes.


○ Alarm display in RUN mode

When R_L | and R_L 2 are low limit alarm, and R_L 3 and R_L 4 are high limit alarm.



■ Input special function [Program mode: / n.5F]

When selecting analog input, this function is to display the calculated actual value by square, root ($\sqrt{-}$), or two unit function (TUF) as display value.



*Display value and mA output value for 598-

*Display value and mA output value for rock

: Display value={((Input value - L - r G (output value)) ×(H - 5C - L - 5C)}+L - 5C

■ Two unit function [Program mode: LUF]


When connecting a pressure sensor, compound pressure which is below atmospheric pressure (0) is for vacuum as mmHg and which is atmospheric pressure or over it is for positive pressure as kg/cm^2 .

Atmospheric pressure is 0kg/cm^2 . When this unit does not display 0kg/cm^2 , you can correct zero-point adjustment function.

When using two unit function, L - 5L is fixed as -760.0

L - 5C parameter is displayed but you cannot set this. You can set H - 5C within 0 to 9999 range.


E.g.)When pressure range is -760.0mmHg to 3.000kg/ cm², and pressure transmitter outputs 4-20mA, set the scale as H - 5[: 3000, dP: 0.000. This unit displays for 4mA input as -760.0, and for 20mA input as 3.000.



■ Digital filter [Program mode: ¬R ... F]

Moving average digital filter is able to stably display and output the noise from input line and irregular signals as software.

- Filter Setting range: 01 to 16
- (When setting as 01, digital filter function does not run.)
- Display cycle is same when executing moving average digital filter.



D1=S1, D2=S2, D3=S3 : Initial operation before averaging 4

		5 5	
D4=	S1+S2+S3+S4	D5=	S2+S3+S4+S5
D4-	4	D3=	4
D6=	S3+S4+S5+S6	D7=	S4+S5+S6+S7
D0-	4	07-	4
D8=	S5+S6+S7+S8		
D0-	4		

Burn out [Program mode: bUrn]

When disconnecting input sensor, you can set the status of transmission output.

- When setting b $\ensuremath{\text{blrn}}$ as $\ensuremath{\text{on}}$, 4-20mA transmission output is fixed as 20mA.
- When setting burn as ${}_{\tt D}{\it FF}$, 4-20mA transmission output is fixed as 4mA.
- XIt is available only for temperature sensor input and 4-20mA transmission output.

Lock [Program mode: Lo[Y]

It limits to check parameter set value and to change it.

	oFF	Lo[I	Lo[2
Program mode	٠	O	0
Monitoring mode	•	•	0

Enable to check/set

 $\mathbb{O}:$ Enable to check, disable to set

O: Disable to check

MIn L $_{D}$, only L $_{D}$ L' parameter displays in program mode.

Digital input [Program mode: di - E, di - E]

By digital input terminal [$d_i - E$] (terminal 12, 13) or digital input key [$d_i - E$] (D.IN3: $\boxtimes + \boxtimes$ for 3 sec), one of three functions executes as the below table.

Function		Operation
AL.r E	Alarm clear	When alarm is ON in RUN mode, it clears alarm forcibly. (It applies only for alarm latch, alarm latch and standby sequence options.) Alarm clear operates only when the value is out of the alarm value range. After clearing alarm, alarm operates its option normally. % For the model without alarm output (KN-10 B), this parameter is not displayed.
Hold	Display HOLD	Temporarily indicated value is stopped in order to check indicated value in unstable input.
EEro	Zero-point adjustment	Set preset display value as 0. This function is related with input correction [I n - b]. When executing zero adjustment function in display value as 4, input correction value [I n - b] is set as -4 automatically.

Communications

■ Communication set [Program mode: Rddr, bRUd]

You can set communication address [Rddr] and communication speed [BRUd] for RS485 communication.

Communication manual


Refer to communication manual for RS485 communication. Visit our web site (www.autonics.com) to download communication manual.


Communication specifications

Item	Specifications
Communication method	RS485 2-wire half duplex
Communication speed (BPS)	9600, 4800, 2400, 1200
Converter	Converter built in RS232
Max. connections	32 units
Communication distance	Max. 1200m (within 700m recommended)
Protocol	Modbus 1.1 RTU
Parity	None
Stop Bit	1-bit
Data length	8-bit

Bar Graph Temperature Indicators


Monitoring Mode





Autonics

Bar Graph Temperature Indicators



Factory Default

Monitoring mode

Parameter	Default	Parameter	Default	Parameter	Default
AL I	099.9	AL 3	000.1	н.реч	
AL 2	099.9	ALY	000.1	L.PEĽ	

Program mode

Parameter	Default	Parameter	Default	Parameter	Default	Parameter	Default
in-P	A ñ A. T	1 n-b	0000	AL - 1	AF I'A	d1 - E	Hold
Unit	٥٢	L-65	0 0 0.0	AL-2	AF I'A	di - 2	Hold
L-rG	0 0.0 0	Н-Ь5	100.0	AL-3	AF 5''	bUrn	oFF
Н-гБ	2 0.0 0	68-	F.bAr	AL-4	AF 5''	Addr	0 1
d.P	0.0	L.oUE	0 0 0.0	А-НУ	001	ьяид	9600
L-5C	000.0	H.o U E	100.0	1 n.5 F	LIn	LoEY	oFF
H-5C	100.0	E 4. 10	5 P	⊼RU.F	04		



Proper Usage

- Follow instructions in 'Cautions during Use'. Otherwise, It may cause unexpected accidents.
- For connecting the power, use the crimp terminal (M3.5, max. 7.2 mm)
- 24 VDC power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Keep away from high voltage lines or power lines to prevent inductive noise.
 Do not use near the equipment which generates strong magnetic force or high frequency noise.
- Install a power switch or circuit breaker in the easily accessible place for supplying or disconnecting the power.
- This unit may be used in the following environments.
 ①Indoors (in the environment condition rated in 'Specifications')
 ②Altitude max. 2,000 m
 ③Pollution degree 2
 ④Installation category II